

MSA for Optimal Reconfiguration and Capacitor Allocation in Radial/Ring Distribution Networks

Emad A. Mohamed^{1,2} *, Al-Attar Ali Mohamed², Yasunori Mitani¹

¹ Department of Electrical Engineering, Kyushu Institute of Technology, 1-1 Sensui-cho, Tobata-ku, Kitakyushu-shi, Fukuoka 804-8550 (Japan)

² Department of Electrical Engineering, Aswan University, 81542 Aswan (Egypt)

Received 30 January 2018 | Accepted 13 April 2018 | Published 1 June 2018



ABSTRACT

This work presents a hybrid heuristic search algorithm called Moth Swarm Algorithm (MSA) in the context of power loss minimization of radial distribution networks (RDN) through optimal allocation and rating of shunt capacitors for enhancing the performance of distribution networks. With MSA, different optimization operators are used to mimic a set of behavioral patterns of moths in nature, which allows for flexible and powerful optimizer. Hence, a new dynamic selection strategy of crossover points is proposed based on population diversity to handle the difference vectors Lévy-mutation to force MSA jump out of stagnation and enhance its exploration ability. In addition, a spiral motion, adaptive Gaussian walks, and a novel associative learning mechanism with immediate memory are implemented to exploit the promising areas in the search space. In this article, the MSA is tested to adapt the objective function to reduce the system power losses, reduce total system cost and consequently increase the annual net saving with inequity constraints on capacitor size and voltage limits. The validation of the proposed algorithm has been tested and verified through small, medium and large scales of standard RDN of IEEE (33, 69, 85-bus) systems and also on ring main systems of 33 and 69-bus. In addition, the obtained results are compared with other algorithms to highlight the advantages of the proposed approach. Numerical results stated that the MSA can achieve optimal solutions for losses reduction and capacitor locations with finest performance compared with many existing algorithms.

KEYWORDS

Radial Distribution System, Optimal Capacitor Location, Loss Reduction, Moth Swarm Algorithm.

DOI: 10.9781/ijimai.2018.05.002

I. INTRODUCTION

MOST of electrical distribution networks feed inductive loads at low voltage levels. This effect leads to higher currents and power losses accompanied by voltage drop whereas about 13% of the total power generation has been considered as line losses [1]. Therefore, these losses must be diminished to improve the power system stability and reliability, power factor and voltage profile. Connecting shunt capacitors is considered as one of the basic methods which has been used in distribution systems to solve such problems [2, 3]. However, the random locating of capacitors can cause more voltage drop and higher power losses. Moreover, the capacitor allocation problem has a combinatorial nature because capacitor locations and sizes are discrete variables [4]. Therefore, several optimization algorithms have been proposed in recent years to solve the optimal shunt capacitor placement and sizing problems in radial and ring distribution systems for maximizing their benefits. Flower pollination algorithm (FPA) [5], particle swarm optimization (PSO) [6, 7], discrete particle swarm optimization (DPSO) [8], genetic algorithm (GA) [9], teaching-learning-based optimization (TLBO) [10], artificial bee colony (ABC) [11], cuckoo search algorithm (CSA) [12], gravitational search algorithm (GSA) [13], modified monkey search (MMS) [14], whale

optimization algorithm (WOA) [15], improved harmony algorithm (IHA) [16], fuzzy-GA [17], direct search algorithm (DSA) [18], differential evolution algorithm (DEA) [19], simulated annealing (SA) [20], plant growth simulation algorithm (PGSA) [21], fuzzy reasoning (FRB) [22], Analytical IP [23], improved binary particle swarm optimization (IBPSO) [24], Mixed-integer nonlinear programming (MINLP) [25] and fuzzy real coded genetic algorithm (FRCGA) [26] have been proposed to solve the capacitor allocation problem. However, some of these algorithms are not highly effective as the power losses still have high values [8, 9]. Other algorithms appear to be effective, but they may not achieve the optimal cost value [5, 10].

Al-Attar et. al [27] has proposed a new optimization technique called the moth swarm algorithm (MSA) which is inspired from the orientation of moths towards moonlight. This algorithm is developed based on the conventional moth flame algorithm by enhancing its exploitation and exploration by applying adaptive cross over levy mutation with associative learning mechanism. It is clear from the literature review that the MSA technique has not been applied to solve the problem of optimal capacitor location in the RDN. Hence, the authors propose to use the MSA method for dealing with the mention problem.

In this paper, MSA is presented to minimize the system power losses, decrease the total cost and maintain the voltage profile for various electrical distribution systems. It is tested on multiple IEEE standard distribution systems i.e., (33 and 69-bus). Furthermore, it is tested on the mesh distribution systems which have two ways

* Corresponding author.

E-mail address: q595506a@mail.kyutech.jp

between generation and consumers and this is more complicated in design and requires complex protection schemes which includes higher investment than RDN. In addition, the obtained results from the proposed approach are compared with those obtained from other algorithms to confirm its superiority. The rest of this work is organized as follows; section.2 provides the objective function formulation. MSA algorithm is represented in section 3. In section.4, the implementing of MSA algorithm for solving the capacitor allocation problem has been presented. Section 5 shows the numerical results of the proposed technique applied on multiple IEEE standard systems. The last section concludes the results and advantages of the proposed method.

II. PROBLEM FORMULATION

A. Load Flow Calculation

RDN creates some negative conditions such as radial meshed networks, unbalanced operation, high R/X ratios and distributed generation. Due to these problems, the Newton Raphson, Gauss Siedel and other conventional load flow algorithms are not effective to solve the load flow calculation of the distribution systems [28]. Therefore, the modern algorithm called backward/forward sweep [28] is used in this work to analyze the power flow in the tested IEEE distribution systems. The line current I_k is calculated from (1) as follows:

$$|I_k| = \left[\frac{P_k + Q_k}{|V_k|} \right] \quad (1)$$

The active power flow (P_{k+1}) and reactive power flow (Q_{k+1}) in RDN are calculated by (2) and (3) derived from single-line diagram as shown in Fig. 1.

$$P_{k+1} = P_k - P_{L(k+1)} - R_k |I_k|^2 \quad (2)$$

$$Q_{k+1} = Q_k - Q_{L(k+1)} - X_k |I_k|^2 \quad (3)$$

where k is the sending end and $k+1$ is the receiving end. Voltages of a transmission line and real power losses in the line can be calculated from (4), (5), and (6) respectively:

$$|V_{k+1}|^2 = |V_k|^2 - 2(R_k P_k + X_k Q_k) + (R_k^2 + X_k^2) |I_k|^2 \quad (4)$$

$$P_{loss(k,k+1)} = R_k |I_k|^2 \quad (5)$$

$$Q_{loss(k,k+1)} = X_k |I_k|^2 \quad (6)$$

The total system loss is calculated by summing all line losses in the system as shown in (7):

$$P_{Tloss} = \sum_{k=1}^{n-1} P_{loss(k,k+1)} \quad (7)$$




Fig. 1. Simple radial distribution system.

B. Objective Functions

The main aim of the objective function of the optimal capacitor placement problem is to minimize the total cost per year by reducing the real power losses and the cost of installing capacitors subjected to voltage and reactive power limits. This paper uses the weighted sum method to evaluate the effectiveness of the proposed approach to find the benefits of optimal allocation and rating of shunt capacitors. The weighted sum method allows the multi-objective to be cast as a single-objective mathematical optimization problem resulting in only one solution, in addition to its lower computational cost (CPU-time). These advantages are more proper for real world problems. Hence, the multi-objective functions have been performed by using the following mathematical statement:

$$f = \text{Min}(F_1 + F_2) \quad (8)$$

where F_1 and F_2 are described as: $F_1 = \text{min}(P_{Tloss})$, $F_2 = \text{min}(Cost)$

where the cost function is defined as:

$$Cost = K_e \sum_{j=1}^l T_j P_j + \sum_{k=1}^n K_{fc} Q_{fc} \quad (9)$$

C. Constraint Conditions

The objective function is subjected to:

1) Voltage Constraint

The buses voltages are the inequality constraints. The bus voltage magnitude of each bus must be maintained within the following range:

$$V_{\min} \leq |V_k| \leq V_{\max} \quad (10)$$

where V_{\max} and V_{\min} are the maximum and minimum values of bus (k) voltages. The lower and upper values are taken as 0.9 and 1.05 Pu, respectively.

2) Total Reactive Power Constraint

The total injected reactive power, which represents the equality constraints must be limited by:

$$Q_{fc} \leq \sum_{k=1}^n Q_{Lk} \quad (11)$$

$$Q_{\text{sys}} + Q_{\text{cap}} = Q_d + Q_{Tloss} \quad (12)$$

Power-flow equations, equality restrictions (2) and (3), can be satisfied during the process of power-flow calculation. In the encoding period, the inequality restrictions (10)–(12) can be satisfied through adding penalty function into the objective function in such a way that it penalizes any violation of the constraints. Consequently, the constrained optimization problem is then converted into an unconstrained form.

III. OVERVIEW OF MSA

The moth swarm algorithm has been presented in 2017 by Al-Attar et. al [27]. It is inspired from the orientation of moths towards moonlight. The available solution of any optimization problem using MSA is performed by the light source position, and its fitness is the luminescence intensity of the light source. Furthermore, the proposed method consists of three main groups, the first one is called pathfinders which is considered a small group of moths (n_p) over the available space of the optimization. The main target of this group is to guide the locomotion of the main swarm by discriminating the best positions as light sources. Prospectors group is the second one which have a

tendency to expatiate in a non-uniform spiral path within the section of the light sources determined by the pathfinders. The last one is the onlookers, this group of moths move directly to the global solution which has been acquired by the prospectors.

The steps of the MSA technique are discussed as follows:

A. Initialization

Initially, the positions of moths are randomly created for dimensional (d) and population number (n) as seen in (13).

$$x_{ij} = rand[0,1] \cdot (x_j^{\max} - x_j^{\min}) + x_j^{\min} \forall i \in \{1,2,\dots,n\}, \\ j \in \{1,2,\dots,d\} \quad (13)$$

where, x_j^{\max} and x_j^{\min} are the upper and lower limits, respectively.

Afterwards, the type of each moth is selected based on the determined fitness. Consequently, the best moths are elected as light sources and the following groups of moths (i.e., the best and worse) will be dealing as prospectors and onlookers, respectively.

B. Reconnaissance Phase

The moths may be concentrated in the regions, which seem to be a good performance. Therefore, the swarm quality for reconnaissance may be decreased during the process of the optimization and this process may lead to a stagnation case. To avoid the early convergence and enhance the solution diversity, a part of the swarm is compelled to determine the less congested area. The moths, which perform this role, update their positions by interacting with each other.

A new strategy for the diversity of solutions is presented to choose the crossover points. Firstly, the normalized dispersal degree σ_j^t of the individuals is measured as follows:

$$\sigma_j^t = \frac{\sqrt{\frac{1}{n_p} \sum_{i=1}^{n_p} (x_{ij}^t - \bar{x}_j^t)^2}}{\bar{x}_j^t} \quad (14)$$

$$\bar{x}_j^t = \frac{1}{n_p} \sum_{i=1}^{n_p} x_{ij}^t$$

where,

Then, the coefficient of variation, which measures the relative dispersion, is calculated as:

$$\mu^t = \frac{1}{d} \sum_{j=1}^d \sigma_j^t \quad (15)$$

Any element of the pathfinder moths exposed to a low dispersal degree will be taken in the group of crossover points C_p , as described below: $j \in C_p$ if $\sigma_j^t \leq \mu^t$

To complete the full trail solution, each host vector (i.e., pathfinder solution) will update the position through the crossover processes by integrating the modified variables of the sub-trail solution into the analogical variables. The full trial solution V_{pj}^t can be defined as:

$$V_{pj}^t = \begin{cases} v_{pj}^t & \text{if } j \in C_p \\ x_{pj}^t & \text{if } j \notin C_p \end{cases} \quad (16)$$

C. Lévy Flights

Lévy flights/motions are random processes based on α -stable distribution with ability to travel over large scale distances using different size of steps. Lévy α -stable distribution strongly linked with heavy-tailed probability density function (PDF), fractal statistics, and anomalous diffusion. The PDF of the individual jumps $\lambda(q) \approx |q|^{-1-\alpha}$ decaying at large generated variable q . The stability/tail index

$\alpha \in [0, 2]$ or so called the characteristic exponent describes the shape of the distribution taper [27]. There are a few special cases that have a close form for the density of the general Lévy distribution, and can be defined as:

- Gaussian or normal distribution, $q \approx N(\mu, \sigma_G^2)$ if density is:

$$f(q) = \frac{1}{\sqrt{2\pi\sigma_G}} \exp\left(-\frac{(q-\mu)^2}{2\sigma_G^2}\right) \quad -\infty < q < \infty \quad (17)$$

- Cauchy distribution, $q \approx cauchy(\sigma, \mu)$ if density is:

$$f(q) = \frac{1}{\pi(\sigma^2 + (q-\mu)^2)} \quad -\infty < q < \infty \quad (18)$$

- A simple version of Lévy distribution, $q \approx Levy(\sigma, \mu)$ if density is:

$$f(q) = \sqrt{\frac{\gamma}{2\pi}} \frac{1}{(q-\mu)^{3/2}} \exp\left(-\frac{\sigma}{2(q-\mu)}\right) \quad 0 < \mu < q < \infty \quad (19)$$

Mantegna's algorithm [27] is used to emulate the α -stable distribution by generating random samples L_i that have the same behavior of the Lévy-flights, as follows:

$$L_i \approx step \oplus Levy(\alpha) \approx 0.01 \frac{u}{|y|^{1/\alpha}} \quad (20)$$

where, step is the scaling size related to the scales of the interest problem, \oplus is the entrywise multiplications, $u = N(0, \sigma_u^2)$ and $y = N(0, \sigma_y^2)$ are two normal stochastic distributions with $\sigma_u = \left[\frac{r(1+\alpha)\sin\pi\alpha/2}{r((1+\alpha)/2\alpha^{(\alpha-1)/2})} \right]$, $\sigma_y = 1$.

D. Difference Vectors Lévy-Mutation

For $n_c \in C_p$ crossover operations points, the proposed algorithm creates the sub-trial vector $v_p = [v_{p1}, v_{p2}, \dots, v_{pn}]$ by perturbing the selected components of the host vector $x_p = [x_{p1}, x_{p2}, \dots, x_{pn}]$, with related components in the donor vectors (e.g. $x_{r1} = [x_{r11}, x_{r12}, \dots, x_{r1n}]$). The Mutation strategy may be used for synthesis such a sub-trial vector, as follows:

$$\vec{v}_p^t = \vec{x}_{r1}^t + L_{p1} (\vec{x}_{r2}^t - \vec{x}_{r3}^t) + L_{p2} (\vec{x}_{r4}^t - \vec{x}_{r5}^t) \\ \forall r^1 \neq r^2 \neq r^3 \neq r^4 \neq r^5 \neq p \in \{1,2,\dots,n_p\} \quad (21)$$

where, L_{p1} and L_{p2} are two independent identical variables used as the mutation scaling factor and generated by a heavy tail Lévy-flights using $(L_p \sim random(n_c) \ominus Levy(\alpha))$. The set of mutually indices ($r1, r2, r3, r4, r5$, and p) are exclusively selected from the pathfinder solutions.

E. Selection Strategy

The fitness value of the full trail solution is determined after finishing the last procedure, and then it is compared with its corresponding host solution. The suitable solutions are selected to continue for the next generation, which is used for minimization problems as follows:

$$\vec{x}_p^{t+1} = \begin{cases} \vec{x}_{pj}^t & \text{if } f(\vec{V}_p^t) \geq f(\vec{x}_p^t) \\ \vec{v}_{pj}^t & \text{if } f(\vec{V}_p^t) < f(\vec{x}_p^t) \end{cases} \quad (22)$$

The probability P_p which is proportional to luminescence intensity f_{ip} can be calculated from (23) and f_{ip} is estimated from the objective function value f_p with minimization problems from (24).

$$p_p = \frac{fit_p}{\sum_{p=1}^{n_p} fit_p} \quad (23)$$

$$fit_p = \begin{cases} \frac{1}{1+f_p} & \text{for } f_p \geq 0 \\ 1+|f_p| & \text{for } f_p < 0 \end{cases} \quad (24)$$

F. Transverse Orientation

The prospector moths are the next best luminescence intensity group of moths. The number of prospectors n_f is proposed to decrease through all iterations T as follows:

$$n_f = \text{round}\left((n - n_p) \times \left(1 - \frac{t}{T}\right)\right) \quad (25)$$

After the pathfinders have finished their search, the information about luminescence intensity is shared with prospectors, which attempt to update its positions in order to discover new light sources. Each prospector moth x_i is soared into the logarithmic spiral path as shown in Fig. 2(a) to make a deep search around the artificial light source x_p , which is chosen on the basis of the probability P_p using (23). The new position of i th prospector moth can be expressed mathematically as follows:

$$\begin{aligned} x_i^{t+1} &= |x_i^t - x_p^t| e^{\theta} \cdot \cos 2\pi\theta + x_p^t \quad \forall p \in \{1, 2, \dots, n_p\} \\ ; \forall i &\in \{n_p + 1, n_p + 2, \dots, n_f\} \end{aligned} \quad (26)$$

where, $\theta \in [r, 1]$ is a random number to define the spiral shape and $r = 1 - t/T$. Although the same formula has been used in Moth-flame Optimization (MFO) [27] algorithm, the MSA is dealing with each variable as an integrated unit. In the MSA model, the moths are changed dynamically. Therefore, any prospector moth uplifts to become pathfinder moth if it discovers a solution with luminescence more than the existing light sources. That means the new lighting sources and moonlight will be presented at the end of this stage.

G. Empyrean Navigation

The diminishing of the number of prospectors during the optimization process increases the onlookers number ($n_o = n - n_f - n_p$). This may lead to an increase in the speed of the convergence rate of MSA towards the global solution. The onlookers are the moths that have the lowest luminescent sources in the swarm. Their main aim for traveling directly to the moon is the most shining solution as shown in Fig. 2(b). In the MSA, the onlookers are forced to search for the hot spots of the prospectors effectively. These onlookers are divided into the two following parts:

The first part, with the size of $n_G = \text{round}(n_o / 2)$, walks according to Gaussian distributions using (5). The new onlooker moth in this subgroup x_i^{t+1} moves with series steps of Gaussian walks, which can be described as follows:

$$\begin{aligned} x_i^{t+1} &= x_i^t + \varepsilon_1 + [\varepsilon_2 \times best_g^t - \varepsilon_3 \times x_i^t] \\ \forall i &\in \{1, 2, \dots, n_G\} \end{aligned} \quad (27)$$

$$\varepsilon_i \sim \text{random}(\text{size}(d)) \oplus N\left(best_g^t, \frac{\log t}{t} \times (x_i^t - best_g^t)\right) \quad (28)$$

Where, ε_i is a random number generated from Gaussian distribution,

ε_2 and ε_3 are random samples drawn from a uniform distribution within the interval $[0, 1]$, $best_g^t$ is the global best solution (moonlight) obtained in the transverse orientation phase. Based on many optimization algorithms, there is a memory to transfer information from the current generation to the next generation. However, the moths may fall into the fire in the real world due to the lack of an evolutionary memory. The performance of moths is intensely affected by the short-term memory and the associative learning [27]. The associative learning has an important role in connection among moths. Therefore, the second part of onlooker moths $n_A = n_o - n_G$ will sweep towards the moon light depending on the associative learning operators with an instantaneous memory to imitate the actual behavior of moths in nature. The instantaneous memory is initialized from the continuous uniform of Gaussian distribution on the range from $x_i^t - x_i^{\min}$ to $x_i^t - x_i^{\max}$. The updating equation of this type can be completed in form:

$$\begin{aligned} x_i^{t+1} &= x_i^t + 0.001 \cdot G[x_i^t - x_i^{\min}, x_i^{\max} - x_i^t] + (1 - \frac{g}{G}) \cdot r_1 \\ &\cdot (best_p^t - x_i^t) + 2g / G \cdot r_2 \cdot (best_g^t - x_i^t) \quad \forall i \in \{1, 2, \dots, n_A\} \end{aligned} \quad (29)$$

where, r_1 and r_2 are random number within the interval $[0, 1]$, $2g/G$ is the social factor, $1-g/G$ is the cognitive factor and $best_p^t$ is a light source selected from the modified swarm based on the probability p_i . It is worth mentioning that the constraints are checked and satisfied after each fitness evaluation in the flowchart of MSA (see Fig. 3).




Fig. 2 Orientation behavior of moth swarm: (a) Moth flying in a spiral path into nearby light source (b) Moth flying in a fixed angle relative to moonlight.

IV. NUMERICAL EXPERIMENTS OF MSA

In order to tune the parameters of the proposed MSA and evaluate its performance in terms of exploitation, exploration, convergence behavior and solution quality, a set of 23 benchmark functions commonly used in literature were tested. The details of these functions are given in [29]. In this section, a swarm of 50 moth with seven pathfinders has been employed over 50 independent runs with a 1000 maximum number of function evaluations for $f_1 - f_{13}$, and 500 iteration for $f_{14} - f_{23}$. MSA is compared with four metaheuristics algorithms, including MPSO [30], Modified Differential Evolution (MDE) [31] approach, MFO [32], and Flower pollination algorithm (FPA) [5], respectively. To maintain comparison consistency, these algorithms are tested with 50-population size under the same conditions and using their standard control-parameters setting as given in Table I. The mean and the standard deviation are used in order to assess the robustness of the algorithms under study.

A. Determination Control Parameters in MSA

In nature, light can be dangerous and a large number of artificial lights will decrease the flight activity of moths. A statistical study has been used to specify the required number of pathfinders, and the obtained results for a swarm of 50 moths at different values of n_p are illustrated at Table II appendix (A). Judging from Table II, it can be seen that, the best required number of pathfinders is approximately 13% of the total populations.




Fig. 3. Flowchart of the proposed MSA.

B. Exploitation Analysis Based on Unimodal Benchmark Functions

The first set of experiments aimed to benchmark the exploitation ability of the proposed MSA. The unimodal function ($f_1 - f_7$), are designed to compare the convergence rate of the search algorithms. In the MSA, pathfinders and prospectors primarily carry out the exploration (global search). The mean and the standard deviation (noted as StDev) are performed as reported in Table III in appendix A. According to the overall rank, although the MSA and MPSO are satisfied the condition of convergence rate and significantly better than other metaheuristic algorithms, the MSA is stronger than MPSO in fine tuning around the global optimum due to its better global search ability. On the other hand, MFO is mainly searched in a small local neighborhood. In addition, the widespread step of the FPA is not a guarantee for obtaining the advanced order.

C. Exploration Analysis Based on Multimodal Benchmark Functions

A test suite has been employed to compare MSA performance with other algorithms at the high-dimensional multimodal functions ($f_8 - f_{13}$), and the final results are summarized in Table IV in appendix (A). It is obvious that, MSA and MDE are clearly escaped from the poor local optimum, and the GMSA approaches the neighborhood of the global optimum at f_8 and hits the exact optimum every time at ($f_9 - f_{11}$). On the other hand, the Lévy-flights updating strategy of FPA maintains a small protection against the premature convergence; whereas the MFO has a low probability to make such a long jumps, which may be the reason for its poor average best fitness.

The experimental study for the low-dimensional multimodal functions ($f_{14} - f_{23}$), given in Table V appendix (A), shows that the MSA and MDE have the best results compared to the rest of the algorithms, while MPSO has difficulties with functions of this kind. Although f_{18} is an easy problem, the GMSA has failed to find the global optimum solution as other algorithms. In the three Shekel functions ($f_{21} - f_{23}$), FPA obtains a better average performance than the other optimizers. In sum, the algorithms achieve a similar performance ranking for both multimodal categories, where MSA is ranked 1st followed by MDE, MPSO, MFO, FPA, respectively. To validate the comparative study, the pairwise Wilcoxon's rank-sum test, a nonparametric statistical test, is carried out at 0.05 significance level to judge whether the results of the GMSA differ from the other algorithms in a statistical method. The p -values of the Wilcoxon's rank-sum, based on outcomes of Tables III-V in appendix (A), are displayed in Table VI appendix (A). In this table, the p -values that are less than 0.05 proved a sufficient evidence against the null hypothesis.

In order to verify the solution quality and further assess the robustness of the proposed algorithms, the graphical analysis of the Analysis of Variance (ANOVA) test for functions f_9, f_8 , and f_{21} are used, as depicted in Fig. 4. The boxplots confirm that MSA achieves, on average, superiority in comparison with the rest of the algorithms.

D. Analysis of the Convergence Behavior

The algorithms under study have been executed on 50 independent runs in order to assess their robustness through the mean and the standard deviation. To investigate the convergence behavior of the best evolution curves for the proposed methods are seen in Fig. 5. Generally, MSA and MPSO have smooth curves with a faster convergence rate more than the other algorithms. Whereas, the MPSO suffers from a premature convergence, caused by particles stagnating around local optima, when handling nonlinear functions. MFO has linear characteristics, meanwhile suffers from excessively slow rate as in f_{10} . In other hand, the MDE and FPA have non-smooth convergence characteristics. We can say that, the developed optimization algorithm

is a deep-PSO, fast-MFO and linear convergence of MDE and FPA. Seven benchmark functions are used to assess the convergence speed of the MSA against the four techniques under study and the well-known PSO [33], group search optimizer (GSO) [33] and modified group search optimizer (MGSO) [34] as shown in Table VII appendix (A). It is clear that MFO gives less computational time cost than the other algorithms. This is because MFO owns one updating equation even though it applies to each component of variables. Although, the MSA contains a number of strategies, but each of them apply to a certain group of the population. Except the small group pathfinders, all moths are dealing with each variable as an integrated unit. In addition, no longer need to store the velocities and personal best solution for each onlooker moth, as in the basic PSO. These properties made the MSA give acceptable computational cost results. The MPSO has a higher cpu-time than the other methods, which may be attributed for the application of the two modifications on all particles. It is important to point out that, the MPSO and MSA have the highest convergence speed and therefore the quickest answer to the problem at hand.




Fig. 4. ANOVA tests for different algorithms.








Fig. 5. Comparison of convergence curves of GMSA and literature algorithms obtained in some of the benchmark problems.

V. RESULTS AND DISCUSSION OF RADIAL DISTRIBUTION SYSTEM

To evaluate the efficiency of the proposed MSA method against power loss and energy cost minimization, The IEEE radial distribution systems of 33 and 69-bus have been applied for this simulation. The MATLAB is used to implement the MSA technique for the optimal capacitor placement problem.

This study includes the annual cost of real power loss and the total capacitor banks. The obtained results are compared with other conventional algorithms over 50 independent runs described as follows.

A. IEEE 33-Bus Test System

To evaluate the impact of the proposed MSA on the medium scale of distribution system, the IEEE 33-bus system has been tested. Fig. 6 shows the single line diagram of this system. The system rated voltage is 12.66 kV. The load and line data are given in [13]. Load flow calculation is run before compensation, the minimum bus voltage is registered as 0.9036 p.u at bus 18 and the total active power loss is 210.98 kW with the annual energy losses cost of 35442.96 \$. Using the proposed MSA method, only three capacitors are allocated at optimal locations at buses 12, 24 and 33 with the size of 450, 600 and 900 kVAR, respectively. As a result, the real power loss is diminished to 137.227 kW as 35.02% of the base case. Furthermore, as seen from Table VIII, MSA reduced the total losses by 34.55 kW compared with Analytical IP [23], 14.52 kW compared with SA [20], 6.81 kW compared with GA [9] and 4.01 kW compared with FRCGA [26]. Also, The annual energy cost is diminished from 35442.96\$ to 23446.98\$ with a net saving of 33.85%, which is the best percentage value compared with 30.29% of GA [9], 31.66% of FRCGA [26], 26.94% of SA [20] and 17.17% of analytical IP [23] as seen in Table VIII in Appendix (A).




Fig. 6. Single line diagram of IEEE 33-bus RDN [13].




Fig. 7. System Voltage Profile for 33-bus system.

In addition, the system voltage profile is improved and the worst bus voltage is enhanced to 0.9329 PU as shown in Fig. 7. These results have validated the performance and effectiveness of the proposed MSA method. Furthermore, the minimization of active power loss and total cost is stabilized with the fast and smooth convergence as shown in Figs. 8 and 9. It is shown that the proposed MSA is more effective than the conventional algorithms under the medium scale of distribution system.




Fig. 8. Power loss convergence of 33-bus system with MSA.




Fig. 9. Total cost convergence of 33-bus system with MSA.

B. IEEE 69-Bus Test System

The proposed MSA is further applied on the IEEE 69-bus system which consists of 69 buses and 68 branches as shown in Fig. 10. The rated line voltage is 12.66 kV and total system load is (1.896MW+j1.347MVAR). The details load and line data are reported in [13]. After running the power flow calculation and before placing the capacitors banks in the RDN, the power loss is obtained at 224.975 kW with the lowest bus voltage at bus 65 is (0.9092 p.u.) and the total energy losses cost is 37800 \$ per year. When applying the proposed method on this RDN, the best active power loss reduction is at 145.404 kW which increased the percentage of loss reduction to 35.37%. This result shows the best value when it is compared with 30.37% of GA [8], 32.22% of PSO [6], 34.66% of DSA [17], 34.95% of TLBO [9], 34.23% of CSA [11], 35.14% of GSA [12] and 35.2% of FPA [5]. This result is considered as the greatest value compared with other algorithms in Table IX Appendix (A). It is found that only three capacitor banks with optimum ratings of 450, 150 and 1200 kVAR have been installed at buses 12, 21 and 61, respectively. Furthermore, the MSA has minimized the total cost per year to 24820.84\$ instead of 37800\$ before compensation. The annual net saving is increased to 34.34% as shown in Table IX in appendix (A). This table displays the statistical performance of the proposed MSA with the best, worst and average values of the total cost for 50 independent runs. Moreover, Fig. 11 confirms the effectivity of the proposed technique by showing the improvement in system voltages. The minimum voltage has been improved to 0.9324 p.u. which is compatible with the voltage constrains. In addition, the fast and effective response of the MSA appears in the convergence curves of total real power loss and total cost in Fig. 12 and 13. The best result obtained from the 50 independent runs for the radial distribution systems were shown in Fig. 8, 9, 12, and 13.




Fig. 10. Single line diagram of IEEE 69-bus RDN [13].




Fig. 11. System Voltage Profile for 69-bus system.




Fig. 12. Power loss convergence rate of 69-bus system with MSA.




Fig. 13. Total cost convergence rate of 69-bus system.

VI. RESULTS FOR RING DISTRIBUTION SYSTEMS

In this section, the proposed MSA optimization method is tested on the complex power systems known as the ring distribution systems, which are more sensitive to variations and uncertainties. Moreover, the ring main system is considered more complex than the radial system in terms of load flow problems and improper coordination problems. The ring distribution systems are built by modifying the standard IEEE 33 and 69-bus.

A. IEEE 33-Bus System

The radial IEEE 33-bus system is reconfigured to the ring main system as shown in Fig. 14. It consists of sectionalized switches from 1 to 32 and tie-switches from 33 to 37. In case of converting the system from radial to ring by using tie-lines (33 to 37), the power loss reduced to 202.68 kW and minimum bus voltage is 0.913 p.u. With optimal reconfiguration (7-11-14-32-37), it can reduce the active power loss by 41.2% and improve the minimum voltage to 0.938 p.u. On the other hand, applying the MSA method on the ring main system for determining the optimal locations and sizes of capacitor banks needs to minimize the power loss with optimal reconfiguration. The result-based MSA shows a good performance as only three locations have been selected at buses 6, 24 and 33 with total reactive power of 1500 kVAR. Furthermore, the total active power loss is reduced with 69.1% from the base case which is better than the other methods as seen in Table X appendix (A). This table summarizes a detail comparison between the MSA, BGSA [35], HSFLA [36], PSO [36], IPSO [36] and ACO [36] for active power loss, minimum voltage and reduction percentage. Moreover, for all bus voltages-based the MSA method are maintained within desirable values and higher than 0.964 p.u as

shown in Fig. 15. In addition, Fig. 16 shows the effective performance of MSA as total power loss converges smoothly to its minimum values without fluctuations.




Fig. 14. Single line diagram of IEEE 33-bus Ring system (Tie switches = 21-8; 9-15; 12-22; 18-33; 25-29).




Fig. 15. Bus Voltage Profile of 33-bus Ring system.




Fig. 16. convergence rate of 33-bus ring system with MSA.

B. IEEE 69-Bus System

The MSA method is further implemented on the large IEEE 69-bus test system after converted to a ring main system as shown in Fig. 17. It consists of sectionalized switches from 1 to 68 (normally closed) and tie-switches from 69 to 73 (normally open). In the base case with tie switches (69-70-71-72-73), the total power loss and the minimum bus voltage are at 224.97 kW and 0.909 p.u, respectively. In case of optimal reconfiguration, it can reduce the active power loss by 59.17% and increase the minimum bus voltage to 0.9877 p.u. as shown in Fig. 18. On the other hand, when installing capacitor banks in the ring main system and implementing the MSA technique for optimizing their locations and sizes gives the great results. Only three locations at buses 11, 50 and 61 have been selected to install capacitors with total reactive power 1500 kVAR. In addition, the total active power loss is diminished by 93.98% from the base case. This result is considered the best comparing with other techniques such as BFO [37], TSA [38], BA [39] and WOA [40] as seen in Table XI in appendix (A). Moreover, the minimum bus voltage increased to 0.99 p.u, which is considered a very

good value as seen in Fig. 18. Furthermore, the effectiveness of the proposed MSA is seen in Fig. 19, which shows the fast convergence of the total active power loss. The best results obtained from the 50 independent runs for the ring distribution systems were shown in Fig. 16 and 19.




Fig. 17. Single line diagram of IEEE 69-bus Ring system (Tie switches = 11-43; 13-21; 15-46; 50-59; 27-65).




Fig. 18. Bus Voltage Profile of 69-bus Ring system.




Fig. 19. Convergence rate of 69-bus ring system with MSA.

VII. CONCLUSION

In this article, a novel MSA paradigm has been presented with two new optimization operators of adaptive crossover based on population diversity and associative learning mechanism with immediate memory, which may be appropriate to hybrid with other algorithms in the future. Twenty-three commonly used benchmarks under different statistical metrics are employed to verify the effectiveness of proper hybridization in terms of convergence, local optima avoidance, robustness, computational cost, exploration, and exploitation. From the obtained results, the final algorithm can be considered a hybrid of algorithms of the PSO, DE, MFO, and PFA in line with the natural characteristics of the moth swarm, and suitable for solving the complex problems. The comparative study with several metaheuristic search techniques, confirms the primacy of the proposed paradigm and its potential to find accurate, fast and robustness solutions.

MSA approach has been successfully applied on the small, medium and large scale electrical distribution systems to solve the problem of capacitors allocation for minimizing the real power losses and annual energy cost, which is considered as an attractive economic issue. MSA superiority is clarified by testing it on radial/ring IEEE distribution networks (33 and 69-bus systems). Furthermore, the proposed MSA can improve the voltage profile at each bus in the systems. Moreover, overall numerical results obtained from the proposed MSA method such as minimum voltage, active power loss, power loss cost, capacitor cost, annual energy cost, net saving cost and CPU time have been compared with other algorithms. The MSA method presents a desirable and superior performance with stable convergence against the other techniques. The applications of the proposed MSA method can be considered as the most recent optimization algorithms for the network reconfiguration and dealing with the protection coordination system in presence of capacitors banks and distribution generation during grid faults are the future scope for this work.

APPENDIX (A)

NOMENCLATURE

| | |
|--------------------------------|--|
| P_k | Real power flow from bus k |
| Q_k | Reactive power flow from bus k |
| P_{Lk} | Real power load connected at bus k |
| Q_{Lk} | Reactive power load connected at bus k |
| $P_{L(k+1)}$ | Real power load connected at bus k+1 |
| $Q_{L(k+1)}$ | Reactive power load connected at bus k+1 |
| R_k | Resistance connected between buses k and k+1 |
| X_k | Reactance connected between buses k and k+1 |
| V_k | Voltage at bus k |
| V_{k+1} | Voltage at bus k+1 |
| K_e | The annual cost co-efficient per unit of power losses [13] |
| K_{fc} | Cost co-efficient in \$/KVAR (3) [17] |
| εI | Random samples drawn from Gaussian stochastic distribution |
| Q_{fc} | Reactive power compensation |
| V_{min} | Minimum bus voltage value |
| V_{max} | Maximum bus voltage value |
| $P_{T loss}$ | Tap setting of transformer |
| n_p | Number of pathfinders moths |
| μ^t | Variation coefficient |
| σ_j^t | Dispersal degree |
| $best_g$ | The global best solution |
| r_1, r_2 | Random number within the interval [0, 1] |
| P_j | The real power loss during jth load level |
| n | The number of candidate buses |
| Q_{fc} | The size of the shunt capacitor |
| $\varepsilon_2, \varepsilon_3$ | Random numbers distributed uniformly within the interval [0,1] |

TABLE I. CONTROL-PARAMETERS VALUES FOR THE DIFFERENT ALGORITHMS

| MPSO | MDE | MFO | FPA |
|---------------------------------------|-----------------------------------|-------------------------|--|
| Personal Coefficient: $c1 = 2$ | Strategy: best/1/bin | Shape constant: $b = 1$ | Probability switch: $P = 0.8$ |
| Global Coefficient: $c2 = 2$ | Mutation factor: $MF = 0.5$ | | standard gamma function: $\lambda = 1.5$ |
| Inertia Damping Ratio: $Wdamp = 0.99$ | Crossover rate: $CR = [0.2, 0.8]$ | | |
| Inertia Weight: $w = 1$ | | | |

TABLE II. PARAMETER SENSITIVITY ANALYSIS OF MSA AT DIFFERENT BENCHMARK FUNCTIONS

| function | $n_p=5$ | | | $n_p=6$ | | | $n_p=7$ | | | $n_p=8$ | | | $n_p=9$ | | |
|--------------|-------------|-------------|------|-------------|-------------|------|-------------|-------------|------|-------------|-------------|------|-------------|-------------|------|
| | Mean | StdDev | rank | Mean | StdDev | rank | Mean | StdDev | rank | Mean | StdDev | rank | Mean | StdDev | rank |
| F1 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 1 |
| F2 | 9.983E-214 | 0 | 1 | 1.6943E-205 | 0 | 2 | 3.5779E-200 | 0 | 3 | 1.3595E-191 | 0 | 4 | 7.3457E-177 | 0 | 5 |
| F3 | 0 | 0 | 1 | 0 | 0 | 1 | 1.8741E-314 | 0 | 3 | 2.2892E-307 | 0 | 4 | 6.3922E-285 | 0 | 5 |
| F4 | 2.4672E-203 | 0 | 1 | 5.1475E-195 | 0 | 2 | 6.9176E-188 | 0 | 3 | 8.3451E-180 | 0 | 4 | 1.4808E-165 | 0 | 5 |
| F5 | 26.6778 | 0.85684 | 5 | 26.3878 | 0.82463 | 3 | 26.3446 | 0.61077 | 2 | 26.5347 | 0.86174 | 4 | 26.0668 | 0.47009 | 1 |
| F6 | 0.00012374 | 9.0761E-005 | 5 | 8.1277E-005 | 6.6125E-005 | 4 | 4.7198E-005 | 2.8043E-005 | 2 | 4.588E-005 | 3.341E-005 | 1 | 6.4774E-005 | 0.00015573 | 3 |
| F7 | 0.00019654 | 0.0002162 | 5 | 0.00019951 | 0.00015317 | 4 | 0.00015027 | 0.00011724 | 2 | 0.00014524 | 0.00015401 | 1 | 0.0001865 | 0.00016547 | 3 |
| F8 | -12561.5104 | 43.5228 | 2 | -12561.5321 | 43.5243 | 3 | -12569.4604 | 0.080905 | 1 | -12442.2964 | 696.4124 | 5 | -12549.6018 | 88.9878 | 4 |
| F9 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 1 |
| F10 | 8.8818E-016 | 0 | 1 | 8.8818E-016 | 0 | 1 | 8.8818E-016 | 0 | 1 | 8.8818E-016 | 0 | 1 | 8.8818E-016 | 0 | 1 |
| F11 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 1 |
| F12 | 0.0034677 | 0.018933 | 3 | 0.0034628 | 0.018931 | 1 | 0.0069211 | 0.026312 | 5 | 0.0034658 | 0.018938 | 2 | 0.0069172 | 0.026305 | 4 |
| F13 | 0.087631 | 0.19905 | 5 | 0.043883 | 0.053288 | 3 | 0.037208 | 0.061412 | 1 | 0.044498 | 0.076444 | 4 | 0.033096 | 0.032425 | 2 |
| F14 | 2.5035 | 2.945 | 5 | 1.6212 | 1.8611 | 1 | 1.8848 | 2.0157 | 2 | 2.3381 | 2.9756 | 3 | 2.4652 | 3.3714 | 4 |
| F15 | 0.0024799 | 0.0060749 | 5 | 0.00049966 | 0.00040909 | 2 | 0.00042689 | 0.00029262 | 1 | 0.00056821 | 0.00038599 | 3 | 0.001143 | 0.0036408 | 4 |
| F16 | -1.0316 | 5.8312E-016 | 1 | -1.0316 | 5.9036E-016 | 1 | -1.0316 | 5.7578E-016 | 1 | -1.0316 | 5.9752E-016 | 1 | -1.0316 | 5.4546E-016 | 1 |
| F17 | 0.39789 | 1.1366E-015 | 1 | 0.39789 | 1.4366E-015 | 1 | 0.39789 | 2.1748E-015 | 1 | 0.39789 | 9.7879E-016 | 1 | 0.39789 | 6.4868E-016 | 1 |
| F18 | 4.8 | 6.8501 | 5 | 3.9 | 4.9295 | 3 | 3.9 | 4.9295 | 3 | 3 | 1.5339E-015 | 1 | 3 | 1.8011E-015 | 1 |
| F19 | -3.8628 | 2.3456E-015 | 1 | -3.8628 | 2.2853E-015 | 1 | -3.8628 | 2.6039E-015 | 1 | -3.8628 | 2.3164E-015 | 1 | -3.8628 | 2.2868E-015 | 1 |
| F20 | -3.2625 | 0.060463 | 4 | -3.2943 | 0.051146 | 2 | -3.3022 | 0.045066 | 1 | -3.2507 | 0.059241 | 5 | -3.2824 | 0.057005 | 3 |
| F21 | -9.9024 | 1.3735 | 3 | -10.1532 | 9.4183E-006 | 1 | -10.1532 | 4.3637E-015 | 1 | -9.7433 | 1.562 | 5 | -9.9024 | 1.3735 | 3 |
| F22 | -9.5125 | 2.3091 | 2 | -9.0358 | 2.0357 | 4 | -9.5125 | 2.3091 | 2 | -9.7351 | 2.0378 | 1 | -9.0033 | 2.8545 | 5 |
| F23 | -9.28 | 2.6391 | 4 | -10.5364 | 8.1263E-006 | 1 | -9.1527 | 2.7367 | 5 | -9.4196 | 2.54 | 3 | -10.313 | 1.2234 | 2 |
| Average rank | | | 2.74 | | | 1.91 | | | | | | 1.91 | | | 2.48 |
| Overall rank | | | 5 | | | 1 | | | | | | 1 | | | 3 |
| | | | | | | | | | | | | | | | 2.65 |
| | | | | | | | | | | | | | | | 4 |

TABLE III. RESULTS OF UNIMODAL BENCHMARK FUNCTIONS FOR DIFFERENT ALGORITHMS

| | MSA | | | MPSO | | | MDE | | | MFO | | | FPA | | |
|--------------|-------------|-------------|------|-------------|-------------|------|-------------|-------------|------|-------------|-------------|------|-------------|-------------|------|
| | Mean | StDev | rank | Mean | StDev | rank | Mean | StDev | rank | Mean | StDev | rank | Mean | StDev | rank |
| F1 | 0 | 0 | 1 | 4.0179E-042 | 1.5634E-041 | 2 | 5.1618E-012 | 2.9283E-012 | 3 | 1333.3334 | 3.4575E+003 | 5 | 489.8355 | 160.965 | 4 |
| F2 | 3.5779E-200 | 0 | 1 | 0.01462316 | 0.0745866 | 3 | 4.9543E-008 | 1.1054E-008 | 2 | 41.6668 | 26.5334 | 5 | 25.4815 | 4.9106 | 4 |
| F3 | 1.8741E-314 | 0 | 1 | 0.12362652 | 0.1646994 | 2 | 25213.1977 | 3871.0339 | 5 | 1.4358E+4 | 9.9687E+003 | 4 | 485.7154 | 177.7229 | 3 |
| F4 | 6.9176E-188 | 0 | 1 | 0.09716659 | 0.06019727 | 2 | 2.0372 | 0.34802158 | 3 | 54.4144 | 11.9746 | 5 | 16.2469 | 1.9700 | 4 |
| F5 | 26.3446 | 0.61077 | 1 | 38.7035 | 29.24275 | 2 | 40.931 | 19.0759 | 3 | 2.6773E+006 | 1.4593E+007 | 5 | 3.2311E+004 | 1.5337E+004 | 4 |
| F6 | 4.7198E-005 | 2.8043E-005 | 3 | 3.142E-019 | 1.6071E-018 | 1 | 5.3249E-012 | 2.6727E-012 | 2 | 666.6834 | 2.5373E+003 | 5 | 518.8479 | 138.4542 | 4 |
| F7 | 0.00015027 | 0.00011724 | 1 | 0.00934203 | 0.0038743 | 2 | 0.0231033 | 0.00569021 | 3 | 3.36868 | 7.9414 | 5 | 0.1329 | 0.0504 | 4 |
| Average rank | | | 1.29 | | | 2 | | | 3 | | | 4.86 | | | 3.86 |
| Overall rank | | | 1 | | | 2 | | | 3 | | | 5 | | | 4 |

TABLE IV. RESULTS OF MULTIMODAL FUNCTIONS WITH MANY LOCAL MINIMA FOR DIFFERENT ALGORITHMS

| | MSA | | | MPSO | | | MDE | | | MFO | | | FPA | | |
|--------------|-------------|----------|------|-------------|-------------|------|-------------|-------------|------|-------------|-------------|------|------------|----------|------|
| | Mean | StDev | rank | Mean | StDev | rank | Mean | StDev | rank | Mean | StDev | rank | Mean | StDev | rank |
| F8 | -12569.4604 | 0.080905 | 1 | -6768.5566 | 652.5301 | 5 | -12544.8116 | 67.8879381 | 2 | -8608.724 | 697.2892 | 3 | -7395.7054 | 243.0420 | 4 |
| F9 | 0 | 0 | 1 | 44.507762 | 11.6937 | 2 | 60.117 | 4.5993 | 3 | 155.092 | 34.3843 | 5 | 135.4706 | 16.0127 | 4 |
| F10 | 8.8818E-016 | 0 | 1 | 0.64426853 | 0.75617291 | 3 | 6.0902E-007 | 1.4946E-007 | 2 | 12.0325 | 9.2836 | 5 | 5.3276 | 0.7895 | 4 |
| F11 | 0 | 0 | 1 | 0.018695461 | 0.047044852 | 3 | 1.0117E-010 | 1.6559E-010 | 2 | 30.1244 | 49.3831 | 5 | 5.8495 | 1.5169 | 4 |
| F12 | 0.0069211 | 0.026312 | 2 | 0.048376744 | 0.070639813 | 3 | 6.5335E-013 | 3.1533E-013 | 1 | 0.350619 | 0.5190 | 4 | 9.5593 | 2.5942 | 5 |
| F13 | 0.037208 | 0.061412 | 2 | 0.046969551 | 0.23055956 | 3 | 3.33E-012 | 1.5799E-012 | 1 | 1.3669E+007 | 7.4867E+007 | 5 | 172.9146 | 205.6159 | 4 |
| Average rank | | | 1.33 | | | 3.17 | | | 1.83 | | | 4.5 | | | 4.17 |
| Overall rank | | | 1 | | | 3 | | | 2 | | | 5 | | | 4 |

TABLE V. RESULTS OF MULTIMODAL FUNCTIONS WITH ONLY A FEW LOCAL MINIMA FOR DIFFERENT ALGORITHMS

| | MSA | | | MPSO | | | MDE | | | MFO | | | FPA | | |
|--------------|------------|-------------|------|------------|-------------|------|------------|-------------|------|------------|-------------|------|------------|-------------|------|
| | Mean | StDev | rank | Mean | StDev | rank | Mean | StDev | rank | Mean | StDev | rank | Mean | StDev | rank |
| F14 | 1.8848 | 2.0157 | 4 | 2.6112459 | 2.0596228 | 5 | 0.998 | 0 | 1 | 1.32869 | 0.7515 | 1 | 0.998 | 3.5971E-005 | 1 |
| F15 | 0.00042689 | 0.00029262 | 2 | 0.00035039 | 0.00023489 | 1 | 0.0006994 | 8.195E-005 | 4 | 0.00114865 | 0.0014 | 5 | 0.00060941 | 0.00012646 | 3 |
| F16 | -1.0316285 | 5.7578E-016 | 1 | -1.0316285 | 6.7752E-016 | 1 | -1.0316285 | 6.7752E-016 | 1 | -1.0316285 | 6.7752E-016 | 1 | -1.0316285 | 7.3634E-008 | 1 |
| F17 | 0.39789 | 2.1748E-015 | 1 | 0.39789 | 0 | 1 | 0.39789 | 0 | 1 | 0.39789 | 0 | 1 | 0.3979 | 1.6453E-006 | 1 |
| F18 | 3.9 | 4.9295 | 5 | 3 | 1.4981E-015 | 1 | 3 | 1.296E-015 | 1 | 3 | 1.6097E-016 | 1 | 3 | 2.7239E-009 | 1 |
| F19 | -3.8628 | 2.6039E-015 | 1 | -3.8628 | 2.7101E-015 | 1 | -3.8628 | 2.7101E-015 | 1 | -3.86278 | 2.7101E-015 | 1 | -3.8628 | 2.2729E-008 | 1 |
| F20 | -3.3022 | 0.045066 | 2 | -3.2863272 | 0.05541509 | 4 | -3.32198 | 5.442E-005 | 1 | -3.20983 | 0.0502 | 5 | -3.2975 | 0.0147 | 3 |
| F21 | -10.1532 | 4.3637E-015 | 1 | -6.7161817 | 3.1908 | 4 | -10.1328 | 0.10940485 | 3 | -5.72036 | 3.1242 | 5 | -10.1432 | 0.0103 | 2 |
| F22 | -9.5125 | 2.3091 | 3 | -6.3183386 | 3.4995 | 5 | -10.4025 | 0.0011901 | 2 | -8.65134 | 2.9966 | 4 | -10.4374 | 0.0551 | 1 |
| F23 | -9.1527 | 2.7367 | 4 | -7.0198746 | 3.8745 | 5 | -10.5363 | 0.00059529 | 1 | -9.41713 | 2.5711 | 3 | -10.4172 | 0.0900 | 2 |
| Average rank | | | 2.4 | | | 2.8 | | | 1.6 | | | 2.7 | | | 1.6 |
| Overall rank | | | 1 | | | 3 | | | 2 | | | 5 | | | 4 |

TABLE VI. P-VALUES CALCULATED FOR WILCOXON'S RANK-SUM TEST ($p \geq 0.05$ HAVE BEEN UNDERLINED)

| | MPSO | MDE | MFO | FPA |
|-----|------------------|-------------|-------------|-------------|
| F1 | <u>0.0742443</u> | 0.0418114 | 0.01228 | 6.263E-010 |
| F2 | 0.0044408 | 0.041814 | 2.0318E-008 | 5.7225E-009 |
| F3 | 4.1048E-005 | 6.263E-010 | 6.263E-010 | 6.263E-010 |
| F4 | 5.5847E-005 | 2.9812E-007 | 6.263E-010 | 1.6501E-008 |
| F5 | 5.7467E-009 | 7.0497E-010 | 7.0497E-010 | 6.2928E-010 |
| F6 | <u>0.0742443</u> | 0.041814 | 0.021081 | 6.263E-010 |
| F7 | 0.00048083 | 0.00048083 | 4.7908E-005 | 0.00048083 |
| F8 | 1.6501E-008 | 1.6501E-008 | 1.6501E-008 | 1.6501E-008 |
| F9 | 7.0165E-010 | 6.263E-010 | 6.263E-010 | 6.263E-010 |
| F10 | 0.0022103 | 0.041814 | 3.6027E-007 | 1.6501E-008 |
| F11 | 0.0081071 | 0.041814 | 3.0022E-005 | 1.6501E-008 |
| F12 | 0.031296 | 0.041819 | 0.0003429 | 1.6567E-008 |
| F13 | 0.03577 | 0.041814 | 0.00044952 | 7.0165E-010 |
| F14 | 4.4603E-007 | 4.448E-007 | 8.304E-007 | 3.2786E-007 |
| F15 | 0.0026421 | 0.00048083 | 0.00048045 | 0.00048083 |
| F16 | 0.0011031 | 0.0011031 | 0.0011031 | 0.015781 |
| F17 | 8.4451E-006 | 8.4451E-006 | 8.4451E-006 | 4.9194E-006 |
| F18 | 2.7033E-008 | 6.9137E-009 | 2.4213E-008 | 1.6501E-008 |
| F19 | 8.4451E-006 | 8.4451E-006 | 8.4451E-006 | 0.00048083 |
| F20 | 0.00056673 | 0.0013295 | 0.0018718 | 0.0031498 |
| F21 | 8.3938E-006 | 2.7552E-006 | 3.1691E-005 | 4.9194E-006 |
| F22 | 6.4387E-005 | 2.885E-006 | 3.4065E-006 | 4.9194E-006 |
| F23 | 5.8609E-006 | 1.2815E-007 | 3.613E-008 | 3.2786E-007 |

TABLE VII. COMPARISONS OF AVERAGE CPU TIME (S) FOR SOME OF BENCHMARK FUNCTIONS

| | MSA | MPSO | MDE | MFO | FPA | MGSO[34] ^a | PSO[33] ^b | GSO[33] ^b |
|-----|--------|---------|---------|--------|--------|-----------------------|----------------------|----------------------|
| F1 | 4.8359 | 10.6167 | 8.1457 | 3.2555 | 4.6371 | 8.98 | 36.3 | 27.6 |
| F5 | 4.9062 | 10.6391 | 8.8892 | 3.8525 | 5.3113 | 18.4 | 37.6 | 27.8 |
| F7 | 5.8201 | 10.4509 | 10.4318 | 4.3053 | 5.4247 | 19.7 | 41.4 | 31.4 |
| F8 | 4.9735 | 9.9465 | 8.3939 | 3.3662 | 4.8413 | 20.5 | 43.0 | 32.7 |
| F9 | 5.0244 | 10.0350 | 8.3013 | 3.4761 | 4.4404 | 10.5 | 71.4 | 50.1 |
| F10 | 5.5109 | 11.0692 | 9.0345 | 4.0075 | 4.9402 | 12.4 | 44.1 | 34.4 |
| F11 | 5.2731 | 10.5239 | 9.0721 | 3.7285 | 4.7920 | 34.8 | 45.4 | 35.9 |

a The experiments were carried out on a PC with a 2.60-GHz Intel Processor and 2.0-GB RAM.

b The experiments were carried out on a PC with a 1.80-GHz Intel Processor and 1.0-GB RAM.

TABLE VIII. COMPARISON RESULTS USING DIFFERENT OPTIMIZATION TECHNIQUES FOR (33-BUS SYSTEM)

| Methods | V_{\min} (P.U) | Optimal location (Bus no.) Optimal size (kVAR) | P_{loss} (kW) | Cost of P_{loss} (\$) | capacitor cost (\$) | Worst Total cost (\$) | Mean Total cost (\$) | Best Total cost (\$) | Total cost reduction | CPU Time (s) |
|--------------------|------------------|---|------------------------|--------------------------------|---------------------|-----------------------|----------------------|----------------------|----------------------|--------------|
| Base Case | 0.903 | - | 210.98 | 35442.9 | | | | | - | - |
| MSA | 0.932 | 12(450),24(600),30(900) | 137.23 | 23054.1 | 392.85 | 23627 | 23534.6 | 23446.98 | 33.85% | 5.4 |
| GA [9] | NA | 7(850), 29(25), 30(900) | 144.04 | 24198.7 | 507.15 | NA | NA | 24705.87 | 30.29% | NA |
| FRCGA [21] | NA | 28(25), 6(475), 29(300), 8(175), 30(400), 9(350) | 141.24 | 23728.3 | 492.86 | NA | NA | 24221.18 | 31.66% | NA |
| Analytical IP [23] | 0.950 | 9(450), 29(800), 30(900) | 171.78 | 28859.0 | 499.35 | NA | NA | 29358.39 | 17.17% | NA |
| SA [20] | 0.959 | 10(450), 30(350), 14(900) | 151.75 | 25494 | 401.052 | NA | NA | 25895.05 | 26.94% | NA |

TABLE IX .COMPARISON RESULTS USING DIFFERENT OPTIMIZATION TECHNIQUES FOR (69-BUS SYSTEM)

| Methods | V_{min} (p.u) | Optimal location (bus no.) Optimal size (kVAR) | Ploss (kW) | Cost of Ploss (\$) | capacitor cost (\$) | Worst Total cost (\$) | Mean Total cost (\$) | Best Total cost (\$) | % Total cost reduction | CPU Time (s) |
|------------------|-----------------|--|------------|-----------------------|------------------------|-----------------------------|-------------------------|-------------------------|------------------------------|-----------------|
| Base Case | 0.909 | - | 224.98 | 37800 | | | | | - | - |
| MSA | 0.932 | 21(150), 12 (450),61(1200) | 145.41 | 24427.99 | 392.85 | 24987.9 | 24908.2 | 24820.8 | 34.3 | 11.42 |
| Fuzzy-GA [17] | 0.936 | 59(100), 61(700), 64(800) | 156.62 | 26312.16 | 424.8 | NA | NA | 26736.9 | 29.2 | NA |
| PSO [6] | NA | 46(241), 47(365), 50(1015) | 152.48 | 25616.64 | 433.99 | NA | NA | 26050.6 | 31.1 | NA |
| DE [18] | 0.931 | 57(150), 58 (50), 61(1000), 60(150), 59(100) | 151.38 | 25431.84 | 316.1 | NA | NA | 25747.9 | 31.8 | NA |
| TLBO [10] | 0.932 | 22(300), 61(1050), 62(300) | 146.35 | 24586.8 | 446.4 | NA | NA | 25033.2 | 33.7 | 15.76 |
| CSA [12] | NA | 21(250), 62(1200) | 147.95 | 24855.6 | 291.5 | NA | NA | 25147.1 | 33.4 | NA |
| GSA [13] | 0.951 | 26(150), 13(150), 15(1050) | 145.9 | 24511.2 | 451.5 | NA | NA | 24962.7 | 33.9 | NA |

TABLE X. COMPARISON RESULTS USING DIFFERENT OPTIMIZATION TECHNIQUES FOR 33-BUS RING SYSTEM

| Techniques | V_{min} (p.u) | Ploss (kW) | % Loss reduction | Optimal location (bus no.) Optimal size (kVAR) | Tie switches |
|------------|-----------------|------------|------------------|---|----------------|
| Base Case | 0.913 | 202.68 | - | - | 33-34-35-36-37 |
| MSA | 0.9642 | 62.68 | 69.1 | 6(150), 24(450),30(900) | 7,11,14,32,37 |
| PSO [36] | 0.9635 | 95.38 | 52.93 | 9(300), 10(300), 31(300), 6(600), 29(600) | 7-10-14-36-37 |
| IPSO [36] | 0.9656 | 98.83 | 51.23 | 5(300), 13(300), 32 (300), 28(1200) | 11-28-33-34-36 |
| IBPSO [36] | 0.9585 | 93.06 | 54.08 | 11(300), 24(300), 32(300), 6(600), 29(600), | 7-9-14-32-37 |
| ACO [36] | 0.9656 | 95.79 | 52.73 | 20(600), 28(450), 29(600) | 7-9-14-32-37 |
| BGSA [35] | 0.956 | 113.56 | 43.97 | 5(NA), 27(NA), 28(NA) | 10-14-28-32-37 |
| HSFLA [36] | 0.9585 | 92.58 | 54.32 | 300(2-4-10-11-18-24-28-29-30) | 7-11-14-32-37 |

TABLE XI. COMPARISON RESULTS USING DIFFERENT OPTIMIZATION TECHNIQUES FOR 69-BUS RING SYSTEM

| Techniques | V_{min} (p.u) | P_{loss} (kW) | % Loss reduction | Optimal location (bus no.) Optimal size (kVAR) | Tie switches (bus no.) |
|------------|-----------------|-----------------|------------------|---|---------------------------|
| Base Case | 0.9092 | 224.97 | - | - | 69-70-71-72-73 |
| MSA | 0.990 | 13.534 | 93.98 | 11(450), 50(150),61(900) | 14-45-52-69-70 |
| BFO [37] | 0.9534 | 33.63 | 85.05 | 11(300), 49(450), 61(900) | 4-56-61-69-70 |
| TSA [38] | 0.956 | 108.94 | 51.58 | 24(100), 45(200), 49(300), 61(400) | 14-20-52-61 |
| BA [39] | 0.9561 | 88.413 | 60.7 | 27(1350), 37(2250), 62(1200) | 11-58-69-70-73 |
| WOA [40] | 0.99 | 66.74 | 70.3 | 50(350), 61(1050), 64(390) | 13-18-56-61-69 |

REFERENCES

- [1] A. Y. Abdelaziz, Ehab S. Ali & Sahar M. Abdelazim, "Flower Pollination Algorithm for Optimal Capacitor Placement and Sizing in Distribution Systems" *Electrical Power Components and Systems*. Vol. 44, no. 5, pp. 544-555, 2016.
- [2] J.B.V. Subrahmanyam, "Optimal capacitor placement in unbalanced radial distribution networks", *J. Theor. Appl. Inform. Technol.* Vol. 6, no. 1, pp. 106-115, 2009.
- [3] T.S. Chung, Ge Shaoyun, "A recursive LP-based approach for optimal capacitor allocation with cost-benefit consideration", *Electric Power Syst. Res.*, Vol. 39, no. 2, pp. 129-136, Nov. 1996.
- [4] Ahmed Elsheikh, Yahya Helmy and Yasmine Abouelseoud, "Optimal Capacitor placement and Sizing in Radial Electric Power System", *Alex. Engineering Journal*. Vol. 53, pp. 809-816, 2014.
- [5] Almoataz Y. Abdelaziz, Ehab S. Ali, Sahar M. Abdelazim, "flower pollination algorithm for optimal capacitor placement and sizing in distribution systems", *Electrical Power Components Systems*. Vol. 44, no. 5, pp. 544-555, 2016.
- [6] K. Prakash, M. Sydulu, "Particle swarm optimization based capacitor placement on radial distribution system", *Proceedings of IEEE Power Engineering Society General Meeting*. pp. 1-5, 2007.
- [7] T. Kerdpol et. al, "Optimization of a battery energy storage system using particle swarm optimization for stand-alone microgrids" *Electrical Power and Energy Systems*. Vol. 81, pp. 32-39, 2016.
- [8] A. Elsheikh, Y. Helmy, Y. Abouelseoud, A. Elsherif, "Optimal capacitor placement and sizing in radial electric power systems", *Alex. Eng J*, Vol. 53, no. 4, pp. 809-816, 2014.
- [9] Sydulu M, Reddy VVK, "Index and GA based optimal location and sizing of distribution system capacitors", *IEEE power engineering society general meeting*. pp. 1-4, June. 2007.
- [10] Sneha Sultana, Provas Kumar Roy, "Optimal capacitor placement in radial distribution systems using teaching learning based optimization", *Elsevier Int. J. Electr. Power Energy Syst.*, Vol. 54, pp. 387-398, 2014.
- [11] R.V. Rao, V.K. Patel, "Optimization of mechanical draft counter flow wet-cooling tower using artificial bee colony algorithm", *Energy Convers Manage*, Vol. 52, no. 7, pp. 2611-2622, 2011.
- [12] Attia A. El-Fergany, Almoataz Y. Abdelaziz, "Cuckoo Search-based Algorithm for Optimal Shunt Capacitors Allocations in Distribution Networks", *Electrical Power Components and Systems*. Vol. 41, no. 16, PP. 1567-1581, 2016.
- [13] Y. Mohamed Shuaiba, M. S. Kalavathib, C. C. Asir, "Optimal capacitor placement in radial distribution system using Gravitational Search Algorithm", *International Journal of Electrical Power & Energy Systems*, Vol. 64, PP.384-397, 2015.
- [14] Felipe Duque, Leonardo Oliveira, Edimar Oliveira et al., "Allocation of capacitor banks in distribution systems through a modified monkey search optimization technique", *International Journal of Electrical Power & Energy Systems*, Vol. 73, PP. 420-432, 2015.
- [15] D. B. Prakash, C. Lakshminarayana "Optimal siting of capacitors in radial distribution network using whale optimization algorithm" *Alexandria Eng J.*, Vol. 56, no. 4, pp. 499-509, 2016.
- [16] E.S. Alia, S.M. Abd Elazima, A.Y. Abdelazizb, "Improved Harmony Algorithm for optimal locations and sizing of capacitors in radial distribution systems", *International Journal of Electrical Power & Energy Systems*. Vol. 79, pp. 275-284, 2016.
- [17] Ying-Tung Hsiao, Chia-Hong Chen, Cheng-Chih Chien, "Optimal capacitor placement in distribution systems using a combination fuzzy-GA method", *International Journal of Electrical Power & Energy Systems*. Vol. 26, no. 7, PP. 501-508, 2004.
- [18] M. Ramalinga Rajua, K.V.S. Ramachandra Murthyb, K. Ravindraa, "Direct search algorithm for capacitive compensation in radial distribution systems", *International Journal of Electrical Power & Energy Systems*. Vol. 42, no. 1, PP. 24-30, 2012.
- [19] S. Neelim "Optimal capacitor placement in distribution networks for loss reduction using differential evolution incorporating dimension reducing load flow for different load levels" *Energetic*, 2012.
- [20] H.D. Chiang, J. Wang, O. Cockings, "Optimal capacitor placements in distribution systems: part 1: a new formulation and the overall problem", *IEEE Trans. Power Deliv*, Vol. 5, pp. 634-642, 1990.
- [21] R. Srinivasas Raa, S.V.L. Narasimhamb, "Optimal capacitor placement in a radial distribution system using Plant Growth Simulation Algorithm", *International Journal of Electrical Power & Energy Systems*, Vol. 33, no. 5, pp. 1133-1139, 2011.
- [22] Ching-Tzong Su, Guor-Rurng Lii, Chih-Cheng Tsai, "Optimal capacitor allocation using fuzzy reasoning and genetic algorithms for distribution systems", *Mathematical and Computer Modelling*, Vol. 33, no. 6-7, pp. 745-757, 2001.
- [23] Ahmed R. Abul'Wafa, "Optimal capacitor allocation in radial distribution systems for loss reduction: a two stage method", *Elsevier Electric Power Syst. Res.*, Vol. 95, pp. 168-174, 2013.
- [24] Mostafa Sedighzadeh, Marzieh Dakhem, Mohammad Sarvi, Hadi Hosseini, "Optimal reconfiguration and capacitor placement for power loss reduction of distribution system using improved binary particle swarm optimization", *Int J Energy Environ*, Vol.73, no.5, pp. 1-11, 2014.
- [25] Sayyad Nojavan, Mehdi Jalali, Kazem Zare, "Optimal allocation of capacitors in radial/mesh distribution systems using mixed integer nonlinear programming approach", *Elsevier Electric Power Syst. Res*. Vol. 107, pp.119-124 , 2014.
- [26] Ahmed R. Abul'Wafa, "Optimal capacitor placement for enhancing voltage stability in distribution systems using analytical algorithm and Fuzzy-Real Coded GA", *International Journal of Electrical Power & Energy Systems*, Vol. 55, pp. 246-252, 2014.
- [27] Al-Attar Ali Mohameda, Yahia S. Mohamedb, Ahmed A.M. El-Gaafaryb, Ashraf M. Hemeida, "Optimal power flow using moth swarm algorithm", *Electric Power Systems Research*, Vol. 142, pp. 190-206, 2017.
- [28] J. A. Michline Ruba and S. Ganesh "Power Flow Analysis for Radial Distribution Systems using Backward/Forward Sweep Method", Vol. 8, no.10, pp. 1621 - 1625, 2014.
- [29] Yao X, Liu Y, Lin G. "Evolutionary programming made faster". *IEEE Trans. Evol. Comput*. Vol. 3, no. 2, pp.82-102, 1999.
- [30] Karami A. "A fuzzy anomaly detection system based on hybrid psokmeans algorithm in content-centric networks", *Neurocomputing*; Vol. 149, pp.1253-1269, 2015.
- [31] L. D. Coelho, V. C. Mariani, J. V. Leite. "Solution of Jiles-Atherton vector hysteresis parameters estimation by modified Differential Evolution approaches", *Expert Syst. Appl.*, Vol. 39, no. 2, pp.2021-2025, 2012.
- [32] Mirjalili S., "Moth-flame optimization algorithm: A novel nature-inspired heuristic paradigm", *Knowledge Based Syst.*; Vol. 89, pp.228-249, 2015]
- [33] He S., Wu Q.H., "an optimization algorithm inspired by animal searching behavior", *IEEE Trans. Evol. Comput*. Vol. 13, no. 5, pp. 973-990, 2009.
- [34] Zare K., Haque M. T., Davoodi E. "Solving non-convex economic dispatch problem with valve point effects using modified group search optimizer method", *Electr. Power Syst. Res*. Vol. 84, no. 1, pp.83-89, 2012.
- [35] H. Reza and F. Rohollah. "Distribution system efficiency improvement using network reconfiguration and capacitor allocation" *Elect.Power and Energy Sys*. Vol. 64, pp. 457-468, 2015.
- [36] M. Sedighzadeh and M.M. mahmoodi, "Optimal Reconfiguration and Capacitor Allocation in Radial Distribution Systems Using the Hybrid Shuffled Frog Leaping Algorithm in the Fuzzy Framework" *Journal of Operation and Automation in Power Engineering*, Vol. 3, no. 1, pp. 56-70, 2015.
- [37] M. Mohammadi, A. Mohammadi Rozbahani, S. Bahmanyar. "Power loss reduction of distribution systems using BFO based optimal reconfiguration along with DG and shunt capacitor placement simultaneously in fuzzy framework", *Journal of Central South University*, Vol. 24, no. 1, pp. 90-103, 2017.
- [38] T. Lantharthong, N. Rugthaicharoencheep. "Network Reconfiguration for Load Balancing in Distribution System with Distributed Generation and Capacitor Placement", *Journal of Electrical, Computer, Energetic, Electronic and Communication Engineering*. Vol. 6, no. 4, 2012.
- [39] Mohammad-Reza Askari, "A New Optimization Framework To Solve The Optimal Feeder Reconfiguration And Capacitor Placement Problems" *Journal of Scientific & Technology Research*. Vol. 4, no. 7, July 2015.
- [40] Sarfaraz Nawaz, A. Bansal, M.P. Sharma, "An Analytical Approach for DG Placement in Reconfigured Distribution Networks", *Journal of Applied Power Engineering*, Vol. 5, no. 3, pp. 137-143, 2016.



Emad A. Mohamed

Emad A. Mohamed received the B.Sc. and M.Sc. degrees in electrical power engineering from Aswan University, Aswan, Egypt in 2005 and 2013 respectively. He is working as a Demonstrator in the Department of Electrical Engineering, Aswan Faculty of Engineering, Aswan University, Aswan, Egypt. Between November 2007 and August 2013, and he is an assistant lecturer from 2013 to 2015. Now, he is a Ph.D. student in Kitakyushu institute of Technology, Japan. He was in a Master Mobility scholarship at Faculté des Sciences et Technologies - Université de Lorraine, France – 1. The scholarship sponsored by FFEEDB ERASMUS MUNDUS. He was a research student from April to October 2015 in Kyushu University, Japan. His research interests are applications of superconducting fault current limiters (SFCLs) on power systems, power system stability, and protection.



Al-Attar Ali Mohamed

Al-Attar Ali Mohamed received his B.Eng., M.Eng, and Ph.D. from Aswan University, Aswan, Egypt in 2010, 2013 and 2017. Currently, he is an assistant professor sponsored in Faculty of Engineering, Aswan University. His research interests are in the area of analysis and design of power systems, optimization, and controls.



Yasunori Mitani

Yasunori Mitani received B.Sc., M.Sc., and D.Eng. degrees in Electrical Engineering from Osaka University, Japan in 1981, 1983 and 1986, respectively. He was a visiting research associate at the University of California, Berkeley, from 1994 to 1995. He is currently a professor at the department of electrical and electronics engineering, Kyushu Institute of Technology (KIT), Japan. At present, he is the head of environmental management center of KIT and vice dean of a graduate school of engineering, KIT. He is also the President of the Institute of Electrical Engineers of Japan (IEEJ), Power and Energy Society.